Certificate of Compliance

This certificate is issued for the following:

Plastic Pipe and Fittings for Wet Pipe Automatic Sprinkler Systems in HC-1 Occupancies

ABN//Instal CT FASER RD FIRE
SDR 11 PP-R CT Pipe and Fittings
Sizes 25 through 125 mm (External Diameter)

Prepared for:

ABN Pipe Systems SLU
Parque Empresarial Medina On
Autovía A-6 KM 152 (Salida 149)
47400 Medina del Campo, Valladolid
Spain

Manufactured at:

ABN Pipe Systems SLU
Parque Empresarial Medina On
Autovía A-6 KM 152 (Salida 149)
47400 Medina del Campo, Valladolid
Spain

FM Approvals Class: 1635 (February 2018)

Approval Identification: PR449812 — Approval Granted: December 24, 2019
Approval Identification: PR456138 — Approval Granted: August 31, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

Member of the FM Global Group