



VLFT.EX15133 Special System Water Control Valves, Deluge Type

[Page Bottom](#)

Special System Water Control Valves, Deluge Type

[See General Information for Special System Water Control Valves, Deluge Type](#)

AG FIRE SPRINKLER SL

EX15133

C/ALFOZ DE BRICIA N 4
POL. IND. VILLALONQUEJAR
09001 BURGOS, SPAIN

Deluge valves, Models "AGCX" DN50, DN65, DN80, DN76, DN100, DN150, DN200 sizes with the following trim configurations:

1. Wet Pilot Line Deluge
2. Dry Pilot Line Deluge
3. Electric Actuation Deluge
4. Wet Pilot Line Single Interlock (w/ supervisory air)
5. Dry Pilot Line Single Interlock (w/ supervisory air)
6. Electric Actuation Single Interlock (w/ supervisory air)

For operation by wet and dry pilot line of sprinklers, height of pilot line above valve limited as shown in the pilot characteristics added to the installation instructions.

Model 400S, 2, 3, 4, 6 and 8 in. sizes, deluge valves for horizontal or vertical installations only with a rated pressure of 250 psig. For operation by dry pilot line, manually, electrically or wet pilot line of spinklers. Height of pilot line above valve limited as shown in the Installation Instructions. For accessories used with these valves, see listing under "Accessories for Special Systems".

Model 400D, 2, 3, 4, 6 and 8 in. sizes, deluge valves for horizontal or vertical installations only with a rated pressure of 250 psig. For operation by dry pilot line, manually, electrically or wet pilot line of spinklers. Height of pilot line above valve limited as shown in the Installation Instructions. For accessories used with these valves, see listing under "Accessories for Special Systems".

Model 400N, 2, 3, 4, 6 and 8 in. sizes, deluge valves for horizontal or vertical installations only with a rated pressure of 250 psig. For operation by dry pilot line, manually, electrically or wet pilot line of spinklers. Height of pilot line above valve limited as shown in the Installation Instructions. For accessories used with these valves, see listing under "Accessories for Special Systems".

[Last Updated](#) on 2015-04-03

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".