



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
GA8106	8.0	Pendent	QR	Job F3-SP 3mm	3/4	Brass, Chrome and Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
GA8106	8.0	In-Rack Pendent	QR	Job F3-SP 3mm	3/4	Brass, Chrome and Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: AG Fire Sprinkler SL, C/Alfoz De Bricia No. 4,
Pol Ind Villalonquéjar, Burgos 09001, Spain

Manufacturing Location: AG Fire Sprinkler SL, C/Alfoz De Bricia No. 4,
Pol Ind Villalonquéjar, Burgos 09001, Spain

FM Approvals Class: 2001, 2005
FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3061359

Approval Granted: November 8, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
GA8118	8.0	Upright	QR	Job F3-SP 3mm	3/4	Brass	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
GA8120	8.0	In-Rack Upright	QR	Job F3-SP 3mm	3/4	Brass	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for:

AG Fire Sprinkler SL, C/Alfoz De Bricia No. 4,
Pol Ind Villalonquéjar, Burgos 09001, Spain

Manufacturing Location:

AG Fire Sprinkler SL, C/Alfoz De Bricia No. 4,
Pol Ind Villalonquéjar, Burgos 09001, Spain

FM Approvals Class: 2001, 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3061359

Approval Granted: November 8, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
GA8156	8.0	Pendent	SR	Job G5 5mm	3/4	Brass, Chrome and Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
GA8156	8.0	In-Rack Pendent	SR	Job G5 5mm	3/4	Brass, Chrome and Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for:

AG Fire Sprinkler SL, C/Alfoz De Bricia No. 4,
Pol Ind Villalonquéjar, Burgos 09001, Spain

Manufacturing Location:

AG Fire Sprinkler SL, C/Alfoz De Bricia No. 4,
Pol Ind Villalonquéjar, Burgos 09001, Spain

FM Approvals Class: 2001, 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3061359

Approval Granted: November 8, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
GA8164	8.0	Upright	SR	Job G5 5mm	3/4	Brass	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
GA8166	8.0	In-Rack Upright	SR	Job G5 5mm	3/4	Brass	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for:

AG Fire Sprinkler SL, C/Alfoz De Bricia No. 4,
Pol Ind Villalonquéjar, Burgos 09001, Spain

Manufacturing Location:

AG Fire Sprinkler SL, C/Alfoz De Bricia No. 4,
Pol Ind Villalonquéjar, Burgos 09001, Spain

FM Approvals Class: 2001, 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3061359

Approval Granted: November 8, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D. B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group