



HLXS.EX15826 Butterfly Valves

[Page Bottom](#)

Butterfly Valves

[See General Information for Butterfly Valves](#)

AG FIRE SPRINKLER SL

EX15826

C/ALFOZ DE BRICIA N 4

POL. IND. VILLALONQUEJAR

09001 BURGOS, SPAIN

Model	Size, NPS	Body Type	Pressure Rating, psig (Bar)	Indicator Post	Supervisory Switch*
Butterfly valve					
GLR 300 W	2-1/2, 3, 4, 6, 8	Wafer	300	—	I, O
GLR 300 G	2-1/2, 3, 4, 6, 8	Groove	300	—	I, O
GLR300T	1, 1-1/4, 1-1/2, 2, 2-1/2	Threaded	300	—	I, O
GLR300G	1-1/4, 1-1/2, 2, 2-1/2	Grooved	300	—	I, O
VM-300-G	2.5 (76.1 mm), 2.5, 3, 4, 5, 5 (139.7 mm), 6, 6 (165.1 mm)	Groove	300	—	I/O
	8, 8 (216.3 mm), 10, 10 (267.4 mm)			—	I/O
	12, 12 (318.4 mm)			—	I/O
VM-300-W	2.5, 3, 4, 5, 6	Wafer	300	—	I/O
	8, 10			—	I/O
	12			—	I/O

Model	Size, NPS	Body Type	Pressure Rating, psig (Bar)	Indicator Post	Supervisory Switch*
Butterfly valve					
VMG300	2,2.5,2.5(76.1mm),3, 4,5,5(139.7mm),6, 6(165.1mm) 8,10,12	Groove	300	N/A	N/A
			250		
			200		
			175		
			300		
			300		
VMW300	2,2.5,3,4,5,6 8	Wafer	300		
VML300	2,2.5,3,4,5,6 8	Lug	300		
VMG300S	2,2.5,2.5(76.1mm) ,3,4,5,5(139.7mm) ,6,6(165.1mm) 8,10,12	Groove	300		I/O
			250		
			200		
			175		
			300		

			300
VMW300S	2,2.5,3,4,5,6 8	Wafer	300
VML300S		Lug	300
VML300S16	2,2.5,3,4,5,6 8		300
	10,12		250
VMT175S	1, 1-1/4, 1-1/2, 2		175

* I = Indoor installation; O = Outdoor installation

Last Updated on 2017-02-08

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".